

# ASSE STANDARD 1021-2001

## ERRATA SHEET

ISSUED: 01/02/2003

### Section IV

#### 4.0 Detailed Requirements

#### ~~4.1 Materials~~

~~Materials shall comply to the applicable sections of the ASSE Reference Document RD-001 "Material Toxicity Requirements for Plumbing Products and Devices."~~

#### 4.1 Markings

Each device shall have the following information marked on it in a location visible after installation:

- a) Manufacturer's name or registered trademark.
- b) Type and/or model.
- c) Critical Level Mark. The marking CL or c/l shall be located on the device.

The markings on the device shall be either etched, cast, molded, stamped or engraved on the body of the device or on a corrosion resistant plate securely attached to the device with a corrosion resistant means.

#### 4.2 Installation Instructions

Complete instructions for installation shall be packaged with the device. Drawings or schematic sketches which would be useful to the installer shall be part of these instructions. These instructions shall provide all information necessary for correct installation.

#### 4.3 Maintenance Instructions

Complete instructions shall be furnished for field maintenance and field repair.