

**ASSE International
Product (Seal) Listing Program**

Factory Audit Inspection Test Report Form (FAITRF)

ASSE 1044-2015

Performance Requirements for Trap Seal Primer –
Drainage Types and Electric Design Types

Manufacturer: _____

Contact Person: _____ **E-mail:** _____

Address: _____

Laboratory: _____ **Laboratory File Number:** _____

Model # Tested: _____

Model Size: _____

Additional models report applies to: _____

Additional Model Information (i.e. orientation, series, end connections, shut-off valves)

Date models received by laboratory: _____ **Date testing began:** _____

Date testing was completed _____

If models were damaged during shipment, describe damages:

Prototype or production sample? _____

Were all tests performed at the selected laboratory? Yes No

If offsite, identify location: _____

General information and instructions for the testing engineer:

The results within this report apply only to the models listed above.

There may be items for which the judgment of the test engineer will be involved. Should there be a question of compliance with that provision of the standard, a conference with the manufacturer should be arranged to enable a satisfactory solution of the question.

Should disagreement persist and compliance remain in question by the test agency, the agency shall, if the product is in compliance with all other requirements of the standard, file a complete report on the questionable items together with the test report, for evaluation by the ASSE Seal Control Board. The Seal Control Board will then review and rule on the question of compliance with the intent of the standard then involved.

Documentation of material compliance must be furnished by the manufacturer. The manufacturer shall furnish to the testing agency, a bill of material which clearly identifies the material of each part included in the product construction. This identification must include any standards which relate thereto.

Section III

3.0 Performance Requirements and Compliance Testing

3.1 Hydrostatic Test for Electric Type

Section not applicable

3.1.2 Trapseal primer pressurized to: _____ psi (_____ kPa)
Time at pressure: _____ min

3.1.3 Any indication of leaking? Yes No Questionable

If no or questionable, explain: _____

In compliance? Yes No Questionable

If no or questionable, explain: _____

3.2 Verification of Manufacturer's Performance Rating

3.2.2.1. For Fixture Tailpiece Trapseal Primer

Section not applicable

Minimum discharge rate of flow through supply line @ 20psi for 1 min per manufacturer:

at 0.5 GPM of faucet flow: _____ GPM (_____ L/min);

at 2.5 GPM of faucet flow: _____ GPM (_____ L/min).

Discharge rate at 0.5 GPM of faucet flow:

Trial 1: _____ GPM (_____ L/min)

Trial 2: _____ GPM (_____ L/min)

Trial 3: _____ GPM (_____ L/min)

Trial 4: _____ GPM (_____ L/min)

Trial 5: _____ GPM (_____ L/min)

3.2.2.2. Fixture Tailpiece Trapseal Criteria

Section not applicable

All trials met mfg's specified ratings? Yes No Questionable

If no or questionable, explain: _____

3.2.2.3. For Ballcock Trapseal Primer

Section not applicable

Make and model of closed coupled water closet:

Flush volume of closed coupled water closet tank: _____ gal/flush (_____ L/flush)

Static line pressure: _____ psi (_____ kPa)

Number of flushes: _____
 Flowing line pressure: _____ psi (_____ kPa)
 Number of flushes: _____

3.2.2.4. Ballcock Trapseal Primer criteria

Section not applicable

Leakage from tank bolt? Yes No Questionable

If no or questionable, explain: _____

Reached minimum rated flow? Yes No Questionable

If no or questionable, explain: _____

Bowl reached full trap depth? Yes No Questionable

If no or questionable, explain: _____

3.2.2.5. For Flushometer Tailpiece/Trap Seal Primer

Section not applicable

Make and model of closed coupled water closet:

Flush volume of closed coupled water closet tank: _____ gal/flush (_____ L/flush)

Flowing line pressure: _____ psi (_____ kPa)

Number of flushes: _____

3.2.2.6. Flushometer Tailpiece/Trap Seal Criteria

Section not applicable

Any leakage? Yes No Questionable

If no or questionable, explain: _____

Reached minimum rated flow? Yes No Questionable

If no or questionable, explain: _____

3.2.2.7. For Electric Trap Seal Primer

Section not applicable

Device pressurized to: _____ psi (_____ kPa)

Cycle "on" time set to: _____ sec

Total number of outlets: _____

Discharge volumes

Summed volumes after 5 cycles of discharge.

Outlet 1		Outlet 2		Outlet 3		Outlet 4		Outlet 5	
oz	mL	oz	mL	oz	mL	oz	mL	oz	mL

Outlet 6		Outlet 7		Outlet 8		Outlet 9		Outlet 10	
oz	mL	oz	mL	oz	mL	oz	mL	oz	mL

For additional outlets, add additional pages.

Is device in compliance with section 3.2? Yes No Questionable

If no or questionable, explain _____

Section IV

4.0 Performance Requirements and Compliance Testing

4.2 Are installation instructions included in the packaging?

Yes No Questionable

If no or questionable, explain: _____

Instructions include:

- Data to guide installer to select appropriate amount of water
- Language to inform installer that electric-design trap seal primers shall be installed with adequate backflow protection meeting all local and state codes.

LISTED LABORATORY: _____

ADDRESS: _____

PHONE: _____ FAX: _____

TEST ENGINEER(S): _____

If applicable:

OUTSOURCED LABORATORY: _____

ADDRESS: _____

PHONE: _____ FAX: _____

TEST ENGINEER(S): _____

Scope of outsourced testing: _____

We certify that the evaluations are based on our best judgments and that the test data recorded is an accurate record of the performance of the device on test.

Signature of the official of the listed laboratory: _____

Signature

Title of the official: _____ Date: _____